



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

**Brian Logel
Clarence Central Schools
9625 Main Street
Clarence, NY 14031**

10/18/2016

Phone: (716) 407-9131
Fax: (716) 407-9137

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 10/5/2016. The results are tabulated on the attached data pages for the following client designated project:

**Project ID: PO 170771
Clarence Center Elementary**

The reference number for these samples is EMSL Order #011606470. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Chemistry Laboratory Manager



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011606470
 CustomerID: CLCS25
 CustomerPO: 170771
 ProjectID: PO 170771

Attn: **Brian Logel**
Clarence Central Schools
9625 Main Street
Clarence, NY 14031

Phone: (716) 407-9131
 Fax: (716) 407-9137
 Received: 10/05/16 9:30 AM

Project: **Clarence Center Elementary**

Analytical Results

| | | | | | | | | |
|----------------------------------|------------------|-----------------------------------|-------------------|--------------|------------------|----------------|----------------------|----------------|
| Client Sample Description | | CC-001 Rm 303 | Collected: | | 9/20/2016 | Lab ID: | | 0001 |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 16.1 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-002 Rm 303 | Collected: | | 9/20/2016 | Lab ID: | | 0002 |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 19.7 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-003 Closet by 303 | Collected: | | 9/20/2016 | Lab ID: | | 0003 |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 57.7 | 2.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | EG |
| Client Sample Description | | CC-004 Drinking Fountain @ 304 | Collected: | | 9/20/2016 | Lab ID: | | 0004 |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 11.8 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-005 Room 305 | Collected: | | 9/20/2016 | Lab ID: | | 0005 |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 16.0 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-006 Room 305 | Collected: | | 9/20/2016 | Lab ID: | | 0006 |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 10.4 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-007 Room 307 | Collected: | | 9/20/2016 | Lab ID: | | 0007 |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 22.5 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011606470
 CustomerID: CLCS25
 CustomerPO: 170771
 ProjectID: PO 170771

Attn: **Brian Logel**
Clarence Central Schools
9625 Main Street
Clarence, NY 14031

Phone: (716) 407-9131
 Fax: (716) 407-9137
 Received: 10/05/16 9:30 AM

Project: **Clarence Center Elementary**

Analytical Results

| Client Sample Description | | CC-008 | Room 307 | Collected: | 9/20/2016 | Lab ID: | 0008 | |
|---------------------------|-----------|--------|------------|------------|------------|---------|---------------|---------|
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 14.2 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-009 | Room 306 | Collected: | 9/20/2016 | Lab ID: | 0009 | |
| 200.8 | Lead | 10.4 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-010 | Room 306 | Collected: | 9/20/2016 | Lab ID: | 0010 | |
| 200.8 | Lead | 3.50 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-011 | Room 306 | Collected: | 9/20/2016 | Lab ID: | 0011 | |
| 200.8 | Lead | 26.1 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-012 | Hall @ 313 | Collected: | 9/20/2016 | Lab ID: | 0012 | |
| 200.8 | Lead | 11.8 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-013 | Room 313 | Collected: | 9/20/2016 | Lab ID: | 0013 | |
| 200.8 | Lead | 21.8 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-014 | Room 313 | Collected: | 9/20/2016 | Lab ID: | 0014 | |
| 200.8 | Lead | 11.9 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011606470
 CustomerID: CLCS25
 CustomerPO: 170771
 ProjectID: PO 170771

Attn: **Brian Logel**
Clarence Central Schools
9625 Main Street
Clarence, NY 14031

Phone: (716) 407-9131
 Fax: (716) 407-9137
 Received: 10/05/16 9:30 AM

Project: **Clarence Center Elementary**

Analytical Results

| | | | | | | | | |
|----------------------------------|------------------|------------------|-------------------|--------------|------------------|----------------|----------------------|----------------|
| Client Sample Description | | CC-015 Rm 315 | Collected: | | 9/20/2016 | Lab ID: | | 0015 |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 20.3 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-016 Rm 315 | Collected: | | 9/20/2016 | Lab ID: | | 0016 |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 12.6 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-017 Rm 316 | Collected: | | 9/20/2016 | Lab ID: | | 0017 |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 22.5 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-018 Rm 316 | Collected: | | 9/20/2016 | Lab ID: | | 0018 |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 12.1 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-019 Rm 314 | Collected: | | 9/20/2016 | Lab ID: | | 0019 |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 28.3 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-020 Rm 314 | Collected: | | 9/20/2016 | Lab ID: | | 0020 |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 19.0 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-021 Rm 312 | Collected: | | 9/20/2016 | Lab ID: | | 0021 |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 13.2 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011606470
 CustomerID: CLCS25
 CustomerPO: 170771
 ProjectID: PO 170771

Attn: **Brian Logel**
Clarence Central Schools
9625 Main Street
Clarence, NY 14031

Phone: (716) 407-9131
 Fax: (716) 407-9137
 Received: 10/05/16 9:30 AM

Project: **Clarence Center Elementary**

Analytical Results

| <i>Client Sample Description</i> | | | | <i>Collected:</i> | <i>9/20/2016</i> | <i>Lab ID:</i> | <i>0022</i> | |
|----------------------------------|------------------|---------------|-----------|-------------------|------------------|----------------|----------------------|----------------|
| Library Work Room | | | | | | | | |
| <i>Method</i> | <i>Parameter</i> | <i>Result</i> | <i>RL</i> | <i>Units</i> | <i>Prep Date</i> | <i>Analyst</i> | <i>Analysis Date</i> | <i>Analyst</i> |
| 200.8 | Lead | 24.6 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| <i>Client Sample Description</i> | | | | <i>Collected:</i> | <i>9/20/2016</i> | <i>Lab ID:</i> | <i>0023</i> | |
| Boys Lav Cluster L | | | | | | | | |
| <i>Method</i> | <i>Parameter</i> | <i>Result</i> | <i>RL</i> | <i>Units</i> | <i>Prep Date</i> | <i>Analyst</i> | <i>Analysis Date</i> | <i>Analyst</i> |
| 200.8 | Lead | 7.62 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| <i>Client Sample Description</i> | | | | <i>Collected:</i> | <i>9/20/2016</i> | <i>Lab ID:</i> | <i>0024</i> | |
| Boys Lav Cluster C | | | | | | | | |
| <i>Method</i> | <i>Parameter</i> | <i>Result</i> | <i>RL</i> | <i>Units</i> | <i>Prep Date</i> | <i>Analyst</i> | <i>Analysis Date</i> | <i>Analyst</i> |
| 200.8 | Lead | 6.53 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| <i>Client Sample Description</i> | | | | <i>Collected:</i> | <i>9/20/2016</i> | <i>Lab ID:</i> | <i>0025</i> | |
| Kitchen Island Sink | | | | | | | | |
| <i>Method</i> | <i>Parameter</i> | <i>Result</i> | <i>RL</i> | <i>Units</i> | <i>Prep Date</i> | <i>Analyst</i> | <i>Analysis Date</i> | <i>Analyst</i> |
| 200.8 | Lead | 20.4 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| <i>Client Sample Description</i> | | | | <i>Collected:</i> | <i>9/20/2016</i> | <i>Lab ID:</i> | <i>0026</i> | |
| Kitchen Hand Sink | | | | | | | | |
| <i>Method</i> | <i>Parameter</i> | <i>Result</i> | <i>RL</i> | <i>Units</i> | <i>Prep Date</i> | <i>Analyst</i> | <i>Analysis Date</i> | <i>Analyst</i> |
| 200.8 | Lead | 29.4 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| <i>Client Sample Description</i> | | | | <i>Collected:</i> | <i>9/20/2016</i> | <i>Lab ID:</i> | <i>0027</i> | |
| Kitchen Triple Sink | | | | | | | | |
| <i>Method</i> | <i>Parameter</i> | <i>Result</i> | <i>RL</i> | <i>Units</i> | <i>Prep Date</i> | <i>Analyst</i> | <i>Analysis Date</i> | <i>Analyst</i> |
| 200.8 | Lead | 76.8 | 4.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | EG |
| <i>Client Sample Description</i> | | | | <i>Collected:</i> | <i>9/20/2016</i> | <i>Lab ID:</i> | <i>0028</i> | |
| Kitchen Triple Sink | | | | | | | | |
| <i>Method</i> | <i>Parameter</i> | <i>Result</i> | <i>RL</i> | <i>Units</i> | <i>Prep Date</i> | <i>Analyst</i> | <i>Analysis Date</i> | <i>Analyst</i> |
| 200.8 | Lead | 78.5 | 4.00 | µg/L | 10/12/2016 | KB | 10/14/2016 | EG |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011606470
 CustomerID: CLCS25
 CustomerPO: 170771
 ProjectID: PO 170771

Attn: **Brian Logel**
Clarence Central Schools
9625 Main Street
Clarence, NY 14031

Phone: (716) 407-9131
 Fax: (716) 407-9137
 Received: 10/05/16 9:30 AM

Project: **Clarence Center Elementary**

Analytical Results

| <i>Client Sample Description</i> | | | | <i>Collected:</i> | <i>9/20/2016</i> | <i>Lab ID:</i> | <i>0029</i> | |
|---|------------------|---------------|-----------|-------------------|------------------|----------------|----------------------|----------------|
| CC-029 Cafeteria Fountain | | | | | | | | |
| <i>Method</i> | <i>Parameter</i> | <i>Result</i> | <i>RL</i> | <i>Units</i> | <i>Prep Date</i> | <i>Analyst</i> | <i>Analysis Date</i> | <i>Analyst</i> |
| 200.8 | Lead | 21.0 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| <i>Client Sample Description</i> | | | | <i>Collected:</i> | <i>9/20/2016</i> | <i>Lab ID:</i> | <i>0030</i> | |
| CC-030 Drinking Fountain at Gang Lav | | | | | | | | |
| <i>Method</i> | <i>Parameter</i> | <i>Result</i> | <i>RL</i> | <i>Units</i> | <i>Prep Date</i> | <i>Analyst</i> | <i>Analysis Date</i> | <i>Analyst</i> |
| 200.8 | Lead | ND | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| <i>Client Sample Description</i> | | | | <i>Collected:</i> | <i>9/20/2016</i> | <i>Lab ID:</i> | <i>0031</i> | |
| CC-031 Gang Lav F #1 | | | | | | | | |
| <i>Method</i> | <i>Parameter</i> | <i>Result</i> | <i>RL</i> | <i>Units</i> | <i>Prep Date</i> | <i>Analyst</i> | <i>Analysis Date</i> | <i>Analyst</i> |
| 200.8 | Lead | 9.39 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| <i>Client Sample Description</i> | | | | <i>Collected:</i> | <i>9/20/2016</i> | <i>Lab ID:</i> | <i>0032</i> | |
| CC-032 Gang Lav F #2 | | | | | | | | |
| <i>Method</i> | <i>Parameter</i> | <i>Result</i> | <i>RL</i> | <i>Units</i> | <i>Prep Date</i> | <i>Analyst</i> | <i>Analysis Date</i> | <i>Analyst</i> |
| 200.8 | Lead | 12.5 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| <i>Client Sample Description</i> | | | | <i>Collected:</i> | <i>9/20/2016</i> | <i>Lab ID:</i> | <i>0033</i> | |
| CC-033 Gang Lav F #3 | | | | | | | | |
| <i>Method</i> | <i>Parameter</i> | <i>Result</i> | <i>RL</i> | <i>Units</i> | <i>Prep Date</i> | <i>Analyst</i> | <i>Analysis Date</i> | <i>Analyst</i> |
| 200.8 | Lead | 8.43 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| <i>Client Sample Description</i> | | | | <i>Collected:</i> | <i>9/20/2016</i> | <i>Lab ID:</i> | <i>0034</i> | |
| CC-034 Janitor Closet | | | | | | | | |
| <i>Method</i> | <i>Parameter</i> | <i>Result</i> | <i>RL</i> | <i>Units</i> | <i>Prep Date</i> | <i>Analyst</i> | <i>Analysis Date</i> | <i>Analyst</i> |
| 200.8 | Lead | 2.91 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| <i>Client Sample Description</i> | | | | <i>Collected:</i> | <i>9/20/2016</i> | <i>Lab ID:</i> | <i>0035</i> | |
| CC-035 Girls Lav Faucet 1 | | | | | | | | |
| <i>Method</i> | <i>Parameter</i> | <i>Result</i> | <i>RL</i> | <i>Units</i> | <i>Prep Date</i> | <i>Analyst</i> | <i>Analysis Date</i> | <i>Analyst</i> |
| 200.8 | Lead | 6.37 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011606470
 CustomerID: CLCS25
 CustomerPO: 170771
 ProjectID: PO 170771

Attn: **Brian Logel**
Clarence Central Schools
9625 Main Street
Clarence, NY 14031

Phone: (716) 407-9131
 Fax: (716) 407-9137
 Received: 10/05/16 9:30 AM

Project: **Clarence Center Elementary**

Analytical Results

| <i>Client Sample Description</i> | | <i>Collected:</i> | | <i>Lab ID:</i> | | | | |
|----------------------------------|------------------|-------------------|-----------|----------------|------------------|----------------|----------------------|----------------|
| CC-036 Girls Gang Lav F-2 | | 9/20/2016 | | 0036 | | | | |
| <i>Method</i> | <i>Parameter</i> | <i>Result</i> | <i>RL</i> | <i>Units</i> | <i>Prep Date</i> | <i>Analyst</i> | <i>Analysis Date</i> | <i>Analyst</i> |
| 200.8 | Lead | 2.19 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| <i>Client Sample Description</i> | | <i>Collected:</i> | | <i>Lab ID:</i> | | | | |
| CC-037 Girls Lav F-3 | | 9/20/2016 | | 0037 | | | | |
| <i>Method</i> | <i>Parameter</i> | <i>Result</i> | <i>RL</i> | <i>Units</i> | <i>Prep Date</i> | <i>Analyst</i> | <i>Analysis Date</i> | <i>Analyst</i> |
| 200.8 | Lead | 6.91 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| <i>Client Sample Description</i> | | <i>Collected:</i> | | <i>Lab ID:</i> | | | | |
| CC-038 Room 204 Sink 1 | | 9/20/2016 | | 0038 | | | | |
| <i>Method</i> | <i>Parameter</i> | <i>Result</i> | <i>RL</i> | <i>Units</i> | <i>Prep Date</i> | <i>Analyst</i> | <i>Analysis Date</i> | <i>Analyst</i> |
| 200.8 | Lead | 36.5 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| <i>Client Sample Description</i> | | <i>Collected:</i> | | <i>Lab ID:</i> | | | | |
| CC-039 Room 204 Bubblers | | 9/20/2016 | | 0039 | | | | |
| <i>Method</i> | <i>Parameter</i> | <i>Result</i> | <i>RL</i> | <i>Units</i> | <i>Prep Date</i> | <i>Analyst</i> | <i>Analysis Date</i> | <i>Analyst</i> |
| 200.8 | Lead | 40.0 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| <i>Client Sample Description</i> | | <i>Collected:</i> | | <i>Lab ID:</i> | | | | |
| CC-040 Room 204 Sink 2 | | 9/20/2016 | | 0040 | | | | |
| <i>Method</i> | <i>Parameter</i> | <i>Result</i> | <i>RL</i> | <i>Units</i> | <i>Prep Date</i> | <i>Analyst</i> | <i>Analysis Date</i> | <i>Analyst</i> |
| 200.8 | Lead | 16.1 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| <i>Client Sample Description</i> | | <i>Collected:</i> | | <i>Lab ID:</i> | | | | |
| CC-041 Room 203 Sink 1 | | 9/20/2016 | | 0041 | | | | |
| <i>Method</i> | <i>Parameter</i> | <i>Result</i> | <i>RL</i> | <i>Units</i> | <i>Prep Date</i> | <i>Analyst</i> | <i>Analysis Date</i> | <i>Analyst</i> |
| 200.8 | Lead | 1.69 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| <i>Client Sample Description</i> | | <i>Collected:</i> | | <i>Lab ID:</i> | | | | |
| CC-042 Room 203 Bubblers | | 9/20/2016 | | 0042 | | | | |
| <i>Method</i> | <i>Parameter</i> | <i>Result</i> | <i>RL</i> | <i>Units</i> | <i>Prep Date</i> | <i>Analyst</i> | <i>Analysis Date</i> | <i>Analyst</i> |
| 200.8 | Lead | 6.37 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011606470
 CustomerID: CLCS25
 CustomerPO: 170771
 ProjectID: PO 170771

Attn: **Brian Logel** Phone: (716) 407-9131
Clarence Central Schools Fax: (716) 407-9137
9625 Main Street Received: 10/05/16 9:30 AM
Clarence, NY 14031

Project: Clarence Center Elementary

Analytical Results

| Client Sample Description | | CC-043 | Room 120 | Collected: | 9/20/2016 | Lab ID: | 0043 | |
|---------------------------|-----------|--------|----------|------------|------------|---------|---------------|---------|
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 1.67 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-044 | Room 120 | Collected: | 9/20/2016 | Lab ID: | 0044 | |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 1.69 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-045 | Room 119 | Collected: | 9/20/2016 | Lab ID: | 0045 | |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 4.03 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-046 | Room 119 | Collected: | 9/20/2016 | Lab ID: | 0046 | |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 1.20 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-047 | Room 118 | Collected: | 9/20/2016 | Lab ID: | 0047 | |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 1.44 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-048 | Room 118 | Collected: | 9/20/2016 | Lab ID: | 0048 | |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | ND | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-049 | Room 117 | Collected: | 9/20/2016 | Lab ID: | 0049 | |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 2.27 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011606470
 CustomerID: CLCS25
 CustomerPO: 170771
 ProjectID: PO 170771

Attn: **Brian Logel**
Clarence Central Schools
9625 Main Street
Clarence, NY 14031

Phone: (716) 407-9131
 Fax: (716) 407-9137
 Received: 10/05/16 9:30 AM

Project: Clarence Center Elementary

Analytical Results

| Client Sample Description | | CC-050 | Room 117 | Collected: | 9/20/2016 | Lab ID: | 0050 | |
|---------------------------|-----------|--------|------------------------|------------|------------|---------|---------------|---------|
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | ND | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-051 | Boys Locker Room | Collected: | 9/20/2016 | Lab ID: | 0051 | |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | ND | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-052 | Room 112 | Collected: | 9/20/2016 | Lab ID: | 0052 | |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 1.07 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-053 | Outside Room 112 | Collected: | 9/20/2016 | Lab ID: | 0053 | |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | ND | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-054 | Gang Restroom near 112 | Collected: | 9/20/2016 | Lab ID: | 0054 | |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | ND | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-055 | Room 106 | Collected: | 9/20/2016 | Lab ID: | 0055 | |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 1.54 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-056 | Room 106 | Collected: | 9/20/2016 | Lab ID: | 0056 | |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 1.55 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvyChemistry2@emsl.com

EMSL Order: 011606470
 CustomerID: CLCS25
 CustomerPO: 170771
 ProjectID: PO 170771

Attn: **Brian Logel**
Clarence Central Schools
9625 Main Street
Clarence, NY 14031

Phone: (716) 407-9131
 Fax: (716) 407-9137
 Received: 10/05/16 9:30 AM

Project: **Clarence Center Elementary**

Analytical Results

| Client Sample Description | | CC-057 | Room 100 | Collected: | 9/20/2016 | Lab ID: | 0057 | |
|---------------------------|-----------|---------|-------------------|------------|------------|---------|---------------|---------|
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 1.18 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-058 | Social Worker | Collected: | 9/20/2016 | Lab ID: | 0058 | |
| 200.8 | Lead | 1.23 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-059 | Outside Room 111 | Collected: | 9/20/2016 | Lab ID: | 0059 | |
| 200.8 | Lead | 1.36 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-060 | Girls Locker Room | Collected: | 9/20/2016 | Lab ID: | 0060 | |
| 200.8 | Lead | ND | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-061 | Girls Locker Room | Collected: | 9/20/2016 | Lab ID: | 0061 | |
| 200.8 | Lead | ND | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-061A | Room 203 Sink #2 | Collected: | 9/20/2016 | Lab ID: | 0062 | |
| 200.8 | Lead | 25.6 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-062 | Room 206 Sink #1 | Collected: | 9/20/2016 | Lab ID: | 0063 | |
| 200.8 | Lead | 25.3 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011606470
 CustomerID: CLCS25
 CustomerPO: 170771
 ProjectID: PO 170771

Attn: **Brian Logel**
Clarence Central Schools
9625 Main Street
Clarence, NY 14031

Phone: (716) 407-9131
 Fax: (716) 407-9137
 Received: 10/05/16 9:30 AM

Project: Clarence Center Elementary

Analytical Results

| Client Sample Description | | CC-063 | Collected: | 9/20/2016 | Lab ID: | 0064 | | |
|---------------------------|-----------|--------|------------|-----------|------------|---------|---------------|---------|
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 15.9 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Room 206 Bubbler | | | | | | | | |
| Client Sample Description | | CC-064 | Collected: | 9/20/2016 | Lab ID: | 0065 | | |
| Room 206 Sink #2 | | | | | | | | |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 13.2 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-065 | Collected: | 9/20/2016 | Lab ID: | 0066 | | |
| Room 205 Sink #1 | | | | | | | | |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 9.54 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-066 | Collected: | 9/20/2016 | Lab ID: | 0067 | | |
| Room 205 Bubbler | | | | | | | | |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 8.93 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-067 | Collected: | 9/20/2016 | Lab ID: | 0068 | | |
| Room 205 Sink #2 | | | | | | | | |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 4.59 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-068 | Collected: | 9/20/2016 | Lab ID: | 0069 | | |
| Room 208 Sink #1 | | | | | | | | |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 21.5 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-069 | Collected: | 9/20/2016 | Lab ID: | 0070 | | |
| Room 208 Bubbler | | | | | | | | |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 14.4 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

| | |
|-------------|-----------|
| EMSL Order: | 011606470 |
| CustomerID: | CLCS25 |
| CustomerPO: | 170771 |
| ProjectID: | PO 170771 |

Attn: **Brian Logel**
Clarence Central Schools
9625 Main Street
Clarence, NY 14031

Phone: (716) 407-9131
 Fax: (716) 407-9137
 Received: 10/05/16 9:30 AM

Project: Clarence Center Elementary

Analytical Results

| Client Sample Description | | CC-070 | Collected: | 9/20/2016 | Lab ID: | 0071 | | |
|---------------------------|-----------|--------|------------|-----------|------------|---------|---------------|---------|
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 147 | 5.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Room 208 Sink #2 | | | | | | | | |
| Client Sample Description | | CC-071 | Collected: | 9/20/2016 | Lab ID: | 0072 | | |
| 200.8 | Lead | 10.1 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Room 207 Sink #1 | | | | | | | | |
| Client Sample Description | | CC-072 | Collected: | 9/20/2016 | Lab ID: | 0073 | | |
| 200.8 | Lead | 12.0 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Room 207 Bubblers | | | | | | | | |
| Client Sample Description | | CC-073 | Collected: | 9/20/2016 | Lab ID: | 0074 | | |
| 200.8 | Lead | 7.82 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Room 207 Sink #2 | | | | | | | | |
| Client Sample Description | | CC-074 | Collected: | 9/20/2016 | Lab ID: | 0075 | | |
| 200.8 | Lead | 14.5 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Room 210 Sink #1 | | | | | | | | |
| Client Sample Description | | CC-075 | Collected: | 9/20/2016 | Lab ID: | 0076 | | |
| 200.8 | Lead | 4.31 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Boys Lav Cluster R | | | | | | | | |
| Client Sample Description | | CC-076 | Collected: | 9/20/2016 | Lab ID: | 0077 | | |
| 200.8 | Lead | 6.17 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Rm 323 | | | | | | | | |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011606470
 CustomerID: CLCS25
 CustomerPO: 170771
 ProjectID: PO 170771

Attn: **Brian Logel**
Clarence Central Schools
9625 Main Street
Clarence, NY 14031

Phone: (716) 407-9131
 Fax: (716) 407-9137
 Received: 10/05/16 9:30 AM

Project: Clarence Center Elementary

Analytical Results

| Client Sample Description | | CC-077 | Collected: | 9/20/2016 | Lab ID: | 0078 | | |
|---------------------------|-----------|----------|------------|-----------|------------|---------|---------------|---------|
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 3.88 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-078 | Collected: | 9/20/2016 | Lab ID: | 0079 | | |
| | | Room 325 | | | | | | |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 21.4 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-079 | Collected: | 9/20/2016 | Lab ID: | 0080 | | |
| | | Room 325 | | | | | | |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 11.7 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-080 | Collected: | 9/20/2016 | Lab ID: | 0081 | | |
| | | Room 326 | | | | | | |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 28.2 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-081 | Collected: | 9/20/2016 | Lab ID: | 0082 | | |
| | | Room 326 | | | | | | |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 23.9 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-082 | Collected: | 9/20/2016 | Lab ID: | 0083 | | |
| | | Room 324 | | | | | | |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 14.8 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-083 | Collected: | 9/20/2016 | Lab ID: | 0084 | | |
| | | Room 324 | | | | | | |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 8.05 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011606470
 CustomerID: CLCS25
 CustomerPO: 170771
 ProjectID: PO 170771

Attn: **Brian Logel**
Clarence Central Schools
9625 Main Street
Clarence, NY 14031

Phone: (716) 407-9131
 Fax: (716) 407-9137
 Received: 10/05/16 9:30 AM

Project: Clarence Center Elementary

Analytical Results

Client Sample Description CC-084
 Girls Lav Cluster Right 1 **Collected:** 9/20/2016 **Lab ID:** 0085

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 16.3 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |

Client Sample Description CC-085
 Girls Lav Cluster Right 2 **Collected:** 9/20/2016 **Lab ID:** 0086

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 4.67 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |

Client Sample Description CC-086
 Girls Lav Cluster Right 3 **Collected:** 9/20/2016 **Lab ID:** 0087

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 5.12 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |

Client Sample Description CC-087
 Girls Lav Cluster Left 4 **Collected:** 9/20/2016 **Lab ID:** 0088

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 8.44 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |

Client Sample Description CC-088
 Fac Lav Cluster **Collected:** 9/20/2016 **Lab ID:** 0089

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 16.0 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |

Client Sample Description CC-089
 Cust Closet @ 333 **Collected:** 9/20/2016 **Lab ID:** 0090

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 25.8 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |

Client Sample Description CC-090
 Room 333 **Collected:** 9/20/2016 **Lab ID:** 0091

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 22.2 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011606470
 CustomerID: CLCS25
 CustomerPO: 170771
 ProjectID: PO 170771

Attn: **Brian Logel**
Clarence Central Schools
9625 Main Street
Clarence, NY 14031

Phone: (716) 407-9131
 Fax: (716) 407-9137
 Received: 10/05/16 9:30 AM

Project: Clarence Center Elementary

Analytical Results

| Client Sample Description | | CC-091 | Room 333 | Collected: | 9/20/2016 | Lab ID: | 0092 | |
|---------------------------|-----------|--------|------------|------------|------------|---------|---------------|---------|
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
| 200.8 | Lead | 22.7 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-092 | Rm 335 | Collected: | 9/20/2016 | Lab ID: | 0093 | |
| 200.8 | Lead | 33.8 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-093 | Rm 335 | Collected: | 9/20/2016 | Lab ID: | 0094 | |
| 200.8 | Lead | 28.3 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-094 | Rm 336 | Collected: | 9/20/2016 | Lab ID: | 0095 | |
| 200.8 | Lead | 6.30 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-095 | Rm 336 | Collected: | 9/20/2016 | Lab ID: | 0096 | |
| 200.8 | Lead | 4.74 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-096 | Rm 334 | Collected: | 9/20/2016 | Lab ID: | 0097 | |
| 200.8 | Lead | 30.8 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |
| Client Sample Description | | CC-097 | Hall @ 334 | Collected: | 9/20/2016 | Lab ID: | 0098 | |
| 200.8 | Lead | 9.07 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011606470
 CustomerID: CLCS25
 CustomerPO: 170771
 ProjectID: PO 170771

Attn: **Brian Logel**
Clarence Central Schools
9625 Main Street
Clarence, NY 14031

Phone: (716) 407-9131
 Fax: (716) 407-9137
 Received: 10/05/16 9:30 AM

Project: Clarence Center Elementary

Analytical Results

| Client Sample Description | | CC-098 | Collected: | 9/20/2016 | Lab ID: | 0099 | | | |
|---------------------------|-----------|-------------------|------------|-----------|------------|---------|---------------|---------|--|
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst | |
| 200.8 | Lead | 28.9 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG | |
| Client Sample Description | | CC-100 | Collected: | 9/20/2016 | Lab ID: | 0100 | | | |
| | | Room 210 Bubblers | | | | | | | |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst | |
| 200.8 | Lead | 16.9 | 1.00 | µg/L | 10/12/2016 | KB | 10/13/2016 | EG | |
| Client Sample Description | | CC-101 | Collected: | 9/20/2016 | Lab ID: | 0101 | | | |
| | | Room 210 Sink 2 | | | | | | | |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst | |
| 200.8 | Lead | 18.9 | 1.00 | µg/L | 10/12/2016 | KB | 10/12/2016 | KB | |
| Client Sample Description | | CC-102 | Collected: | 9/20/2016 | Lab ID: | 0102 | | | |
| | | Room 209 Sink 1 | | | | | | | |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst | |
| 200.8 | Lead | 7.90 | 1.00 | µg/L | 10/12/2016 | KB | 10/12/2016 | KB | |
| Client Sample Description | | CC-103 | Collected: | 9/20/2016 | Lab ID: | 0103 | | | |
| | | Room 209 Bubblers | | | | | | | |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst | |
| 200.8 | Lead | 5.73 | 1.00 | µg/L | 10/12/2016 | KB | 10/12/2016 | KB | |
| Client Sample Description | | CC-104 | Collected: | 9/20/2016 | Lab ID: | 0104 | | | |
| | | Room 209 Sink 2 | | | | | | | |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst | |
| 200.8 | Lead | 14.9 | 1.00 | µg/L | 10/12/2016 | KB | 10/12/2016 | KB | |
| Client Sample Description | | CC-105 | Collected: | 9/20/2016 | Lab ID: | 0105 | | | |
| | | Room 212 Sink 1 | | | | | | | |
| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst | |
| 200.8 | Lead | 22.2 | 1.00 | µg/L | 10/12/2016 | KB | 10/12/2016 | KB | |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011606470
 CustomerID: CLCS25
 CustomerPO: 170771
 ProjectID: PO 170771

Attn: **Brian Logel**
Clarence Central Schools
9625 Main Street
Clarence, NY 14031

Phone: (716) 407-9131
 Fax: (716) 407-9137
 Received: 10/05/16 9:30 AM

Project: Clarence Center Elementary

Analytical Results

Client Sample Description CC-106 **Collected:** 9/20/2016 **Lab ID:** 0106
 Room 212 Bubblers

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 10.1 | 1.00 | µg/L | 10/12/2016 | KB | 10/12/2016 | KB |

Client Sample Description CC-107 **Collected:** 9/20/2016 **Lab ID:** 0107
 Room 212 Sink 2

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 18.7 | 1.00 | µg/L | 10/12/2016 | KB | 10/12/2016 | KB |

Client Sample Description CC-108 **Collected:** 9/20/2016 **Lab ID:** 0108
 Room 211 Sink 1

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 33.1 | 1.00 | µg/L | 10/12/2016 | KB | 10/12/2016 | KB |

Client Sample Description CC-109 **Collected:** 9/20/2016 **Lab ID:** 0109
 Room 211 Bubblers

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 9.61 | 1.00 | µg/L | 10/12/2016 | KB | 10/12/2016 | KB |

Client Sample Description CC-110 **Collected:** 9/20/2016 **Lab ID:** 0110
 Room 211 Sink 2

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 13.1 | 1.00 | µg/L | 10/12/2016 | KB | 10/12/2016 | KB |

Client Sample Description CC-111 **Collected:** 9/20/2016 **Lab ID:** 0111
 Main Water Service

| Method | Parameter | Result | RL | Units | Prep Date | Analyst | Analysis Date | Analyst |
|--------|-----------|--------|------|-------|------------|---------|---------------|---------|
| 200.8 | Lead | 365 | 20.0 | µg/L | 10/12/2016 | KB | 10/12/2016 | KB |

Definitions:

ND - indicates that the analyte was not detected at the reporting limit
 RL - Reporting Limit (Analytical)