



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

---

Attn:

**Brian Logel**  
**Clarence Central Schools**  
**9625 Main Street**  
**Clarence, NY 14031**

12/29/2016

Phone: (716) 407-9131  
Fax: (716) 407-9137

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 11/2/2016. The results are tabulated on the attached data pages for the following client designated project:

**Project ID: PO 170771**  
**High School**

The reference number for these samples is EMSL Order #011607647. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

---

Phillip Worby, Chemistry Laboratory Manager



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.  
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 187

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011607647

CustomerID: CLCS25

CustomerPO: 170771

ProjectID: PO 170771

Attn: **Brian Logel**  
**Clarence Central Schools**  
**9625 Main Street**  
**Clarence, NY 14031**

Phone: (716) 407-9131  
 Fax: (716) 407-9137  
 Received: 11/02/16 10:00 AM

Project: High School

**Analytical Results**

**Client Sample Description** HS-001  
 KITCHEN SINK **Collected:** 10/18/2016 **Lab ID:** 0001

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.32	1.00	µg/L	12/21/2016	CB	12/27/2016	BB

**Client Sample Description** HS-002  
 KITCHEN SINK **Collected:** 10/18/2016 **Lab ID:** 0002

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.57	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-003  
 KITCHEN SINK **Collected:** 10/18/2016 **Lab ID:** 0003

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.72	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-004  
 KITCHEN SINK **Collected:** 10/18/2016 **Lab ID:** 0004

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.10	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-005  
 DOCK WOMENS RESTROOM **Collected:** 10/18/2016 **Lab ID:** 0005

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-006  
 DOCK MENS RESTROOM **Collected:** 10/18/2016 **Lab ID:** 0006

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-007  
 FOOD COURT SINK 1 **Collected:** 10/18/2016 **Lab ID:** 0007

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.03	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011607647

CustomerID: CLCS25

CustomerPO: 170771

ProjectID: PO 170771

Attn: **Brian Logel**  
**Clarence Central Schools**  
**9625 Main Street**  
**Clarence, NY 14031**

Phone: (716) 407-9131  
 Fax: (716) 407-9137  
 Received: 11/02/16 10:00 AM

Project: High School

**Analytical Results**

**Client Sample Description** HS-008  
 FOOD COURT SINK 2 **Collected:** 10/18/2016 **Lab ID:** 0008

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.79	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-009  
 BREAK ROOM SINK **Collected:** 10/18/2016 **Lab ID:** 0009

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-010  
 FOOD COURT SINK 3 **Collected:** 10/18/2016 **Lab ID:** 0010

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.17	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-011  
 FOOD COURT SINK 4 **Collected:** 10/18/2016 **Lab ID:** 0011

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.29	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-012  
 FOOD COURT SINK 5 **Collected:** 10/18/2016 **Lab ID:** 0012

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.42	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-013  
 FOOD COURT TRAY LINE SINK **Collected:** 10/18/2016 **Lab ID:** 0013

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.39	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-014  
 NURSE OFFICE HALLWAY DRINK  
 FOUNTAIN **Collected:** 10/18/2016 **Lab ID:** 0014

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011607647

CustomerID: CLCS25

CustomerPO: 170771

ProjectID: PO 170771

Attn: **Brian Logel**  
**Clarence Central Schools**  
**9625 Main Street**  
**Clarence, NY 14031**

Phone: (716) 407-9131  
 Fax: (716) 407-9137  
 Received: 11/02/16 10:00 AM

Project: High School

**Analytical Results**

**Client Sample Description** HS-015  
 NURSE OFFICE HALLWAY BOTTLE FILLER  
**Collected:** 10/18/2016 **Lab ID:** 0015

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-016  
 109 GIRLS 1 HANDICAP RESTROOM  
**Collected:** 10/18/2016 **Lab ID:** 0016

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.50	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-017  
 109 GIRLS 2 HANDICAP RESTROOM  
**Collected:** 10/18/2016 **Lab ID:** 0017

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.76	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-018  
 109 GIRLS 3 HANDICAP RESTROOM  
**Collected:** 10/18/2016 **Lab ID:** 0018

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	23.3	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-019  
 109 GIRLS 4 HANDICAP RESTROOM  
**Collected:** 10/18/2016 **Lab ID:** 0019

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	12.5	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-020  
 109 FACULTY WOMEN RESTROOM  
**Collected:** 10/18/2016 **Lab ID:** 0020

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-021  
 109 FACULTY WOMEN RESTROOM  
**Collected:** 10/18/2016 **Lab ID:** 0021

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011607647

CustomerID: CLCS25

CustomerPO: 170771

ProjectID: PO 170771

Attn: **Brian Logel**  
**Clarence Central Schools**  
**9625 Main Street**  
**Clarence, NY 14031**

Phone: (716) 407-9131  
 Fax: (716) 407-9137  
 Received: 11/02/16 10:00 AM

Project: High School

**Analytical Results**

**Client Sample Description** HS-022  
109 FACULTY MEN RESTROOM  
**Collected:** 10/18/2016 **Lab ID:** 0022

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-023  
109 FACULTY MEN RESTROOM  
**Collected:** 10/18/2016 **Lab ID:** 0023

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-024  
120 BOYS GANG LAV  
**Collected:** 10/18/2016 **Lab ID:** 0024

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.38	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-025  
ROOM 124 - 1  
**Collected:** 10/18/2016 **Lab ID:** 0025

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	30.1	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-026  
ROOM 124 - 2  
**Collected:** 10/18/2016 **Lab ID:** 0026

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	53.0	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-027  
ROOM 124 - 3  
**Collected:** 10/18/2016 **Lab ID:** 0027

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	30.8	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-028  
ROOM 124 - 4  
**Collected:** 10/18/2016 **Lab ID:** 0028

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	81.2	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011607647

CustomerID: CLCS25

CustomerPO: 170771

ProjectID: PO 170771

Attn: **Brian Logel**  
**Clarence Central Schools**  
**9625 Main Street**  
**Clarence, NY 14031**

Phone: (716) 407-9131  
 Fax: (716) 407-9137  
 Received: 11/02/16 10:00 AM

Project: High School

**Analytical Results**

**Client Sample Description** HS-029  
 ROOM 127 WASH TUB  
**Collected:** 10/18/2016 **Lab ID:** 0029

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	21.2	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-030  
 ROOM 130 SINK 1  
**Collected:** 10/18/2016 **Lab ID:** 0030

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	12.3	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-031  
 ROOM 130 SINK 2  
**Collected:** 10/18/2016 **Lab ID:** 0031

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.59	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-032  
 ROOM 130 SINK 3  
**Collected:** 10/18/2016 **Lab ID:** 0032

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	15.4	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-033  
 ROOM 130 SINK 4  
**Collected:** 10/18/2016 **Lab ID:** 0033

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	8.26	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-034  
 ROOM 132 SINK 1  
**Collected:** 10/18/2016 **Lab ID:** 0034

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.69	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-035  
 ROOM 132 SINK 2  
**Collected:** 10/18/2016 **Lab ID:** 0035

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.51	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011607647

CustomerID: CLCS25

CustomerPO: 170771

ProjectID: PO 170771

Attn: **Brian Logel**  
**Clarence Central Schools**  
**9625 Main Street**  
**Clarence, NY 14031**

Phone: (716) 407-9131  
 Fax: (716) 407-9137  
 Received: 11/02/16 10:00 AM

Project: High School

**Analytical Results**

**Client Sample Description** HS-036  
ROOM 132 SINK 3  
**Collected:** 10/18/2016 **Lab ID:** 0036

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	19.0	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-037  
ROOM 134 SINK 1  
**Collected:** 10/18/2016 **Lab ID:** 0037

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	22.7	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-038  
ROOM 134 SINK 2  
**Collected:** 10/18/2016 **Lab ID:** 0038

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	10.4	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-039  
ROOM 134 DRINK  
**Collected:** 10/18/2016 **Lab ID:** 0039

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-040  
ROOM 134 SINK 3  
**Collected:** 10/18/2016 **Lab ID:** 0040

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-041  
ROOM 134 SHOP RESTROOM  
**Collected:** 10/18/2016 **Lab ID:** 0041

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.30	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-042  
ROOM 135 ROBO ROOM  
**Collected:** 10/18/2016 **Lab ID:** 0042

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.89	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	011607647
CustomerID:	CLCS25
CustomerPO:	170771
ProjectID:	PO 170771

Attn: **Brian Logel**  
**Clarence Central Schools**  
**9625 Main Street**  
**Clarence, NY 14031**

Phone: (716) 407-9131  
 Fax: (716) 407-9137  
 Received: 11/02/16 10:00 AM

Project: **High School****Analytical Results**

**Client Sample Description** HS-043  
ROOM 140 PHOTO 1  
**Collected:** 10/18/2016 **Lab ID:** 0043

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.72	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-044  
ROOM 140 PHOTO 2  
**Collected:** 10/18/2016 **Lab ID:** 0044

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.90	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-045  
ROOM 140 CHEM ROOM  
**Collected:** 10/18/2016 **Lab ID:** 0045

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.59	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-046  
ROOM 129 HALL DRINK  
**Collected:** 10/18/2016 **Lab ID:** 0046

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	16.4	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-047  
206 MENS HALL RESTROOM  
**Collected:** 10/18/2016 **Lab ID:** 0047

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	16.6	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-048  
206 HALL DRINK FOUNT  
**Collected:** 10/18/2016 **Lab ID:** 0048

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-049  
GIRLS LOCKER ROOM POOL (RIGHT SINK)  
**Collected:** 10/18/2016 **Lab ID:** 0049

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.07	1.00	µg/L	12/21/2016	CB	12/22/2016	BB



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011607647

CustomerID: CLCS25

CustomerPO: 170771

ProjectID: PO 170771

Attn: **Brian Logel**  
**Clarence Central Schools**  
**9625 Main Street**  
**Clarence, NY 14031**

Phone: (716) 407-9131  
 Fax: (716) 407-9137  
 Received: 11/02/16 10:00 AM

Project: High School

**Analytical Results**

**Client Sample Description** HS-050  
 GIRLS LOCKER ROOM POOL (LEFT SINK) **Collected:** 10/18/2016 **Lab ID:** 0050

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-051  
 POOL **Collected:** 10/18/2016 **Lab ID:** 0051

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-052  
 BOYS LOCKER ROOM (RIGHT) POOL **Collected:** 10/18/2016 **Lab ID:** 0052

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-053  
 BOYS LOCKER ROOM (LEFT) POOL **Collected:** 10/18/2016 **Lab ID:** 0053

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.17	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-054  
 GIRLS LOCKER ROOM COACHES OFFICE **Collected:** 10/18/2016 **Lab ID:** 0054

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-055  
 GIRLS LOCKER ROOM **Collected:** 10/18/2016 **Lab ID:** 0055

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-056  
 GIRLS LOCKER ROOM (RIGHT) **Collected:** 10/18/2016 **Lab ID:** 0056

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011607647

CustomerID: CLCS25

CustomerPO: 170771

ProjectID: PO 170771

Attn: **Brian Logel**  
**Clarence Central Schools**  
**9625 Main Street**  
**Clarence, NY 14031**

Phone: (716) 407-9131  
 Fax: (716) 407-9137  
 Received: 11/02/16 10:00 AM

Project: High School

**Analytical Results**

**Client Sample Description** HS-057  
 GIRLS LOCKER ROOM (CENTER) **Collected:** 10/18/2016 **Lab ID:** 0057

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/23/2016	CB	12/23/2016	BB

**Client Sample Description** HS-058  
 GIRLS LOCKER ROOM (LEFT) **Collected:** 10/18/2016 **Lab ID:** 0058

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/23/2016	CB	12/23/2016	BB

**Client Sample Description** HS-059  
 333A **Collected:** 10/18/2016 **Lab ID:** 0059

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/23/2016	CB	12/23/2016	BB

**Client Sample Description** HS-060  
 333 **Collected:** 10/18/2016 **Lab ID:** 0060

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/23/2016	CB	12/23/2016	BB

**Client Sample Description** HS-061  
 GYM HALL **Collected:** 10/18/2016 **Lab ID:** 0061

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-062  
 GIRLS TEAM ROOM (RIGHT) **Collected:** 10/18/2016 **Lab ID:** 0062

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-063  
 GIRLS TEAM ROOM (LEFT) **Collected:** 10/18/2016 **Lab ID:** 0063

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.45	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	011607647
CustomerID:	CLCS25
CustomerPO:	170771
ProjectID:	PO 170771

Attn: **Brian Logel**  
**Clarence Central Schools**  
**9625 Main Street**  
**Clarence, NY 14031**

Phone: (716) 407-9131  
 Fax: (716) 407-9137  
 Received: 11/02/16 10:00 AM

Project: **High School****Analytical Results**

**Client Sample Description** HS-064  
 BOYS LOCKER ROOM COACHES OFFICE  
**Collected:** 10/18/2016 **Lab ID:** 0064

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/21/2016	CB	12/22/2016	BB

**Client Sample Description** HS-065  
 BOYS LOCKER ROOM (RIGHT)  
**Collected:** 10/18/2016 **Lab ID:** 0065

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/21/2016	CB	12/21/2016	EG

**Client Sample Description** HS-066  
 BOYS LOCKER ROOM (LEFT)  
**Collected:** 10/18/2016 **Lab ID:** 0066

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/21/2016	CB	12/21/2016	EG

**Client Sample Description** HS-067  
 BOYS LOCKER ROOM  
**Collected:** 10/18/2016 **Lab ID:** 0067

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/21/2016	CB	12/21/2016	EG

**Client Sample Description** HS-068  
 BOYS TEAM ROOM  
**Collected:** 10/18/2016 **Lab ID:** 0068

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.06	1.00	µg/L	12/21/2016	CB	12/21/2016	EG

**Client Sample Description** HS-069  
 BOYS LAV - GYM (RIGHT) HALL  
**Collected:** 10/18/2016 **Lab ID:** 0069

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-070  
 BOYS LAV - GYM HALL RIGHT CENTER  
**Collected:** 10/18/2016 **Lab ID:** 0070

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	011607647
CustomerID:	CLCS25
CustomerPO:	170771
ProjectID:	PO 170771

Attn: **Brian Logel**  
**Clarence Central Schools**  
**9625 Main Street**  
**Clarence, NY 14031**

Phone: (716) 407-9131  
 Fax: (716) 407-9137  
 Received: 11/02/16 10:00 AM

Project: High School

**Analytical Results**

**Client Sample Description** HS-071  
 BOYS LAV - GYM HALL (LEFT CENTER) **Collected:** 10/18/2016 **Lab ID:** 0071

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-072  
 BOYS LAV - GYM HALL (LEFT) **Collected:** 10/18/2016 **Lab ID:** 0072

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-073  
 GIRLS LAV - GYM HALL (RIGHT) **Collected:** 10/18/2016 **Lab ID:** 0073

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-074  
 GIRLS LAV - GYM HALL (RIGHT CENTER) **Collected:** 10/18/2016 **Lab ID:** 0074

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-075  
 GIRLS LAV - GYM HALL (LEFT CENTER) **Collected:** 10/18/2016 **Lab ID:** 0075

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-076  
 GIRLS LAV - GYM HALL (LEFT) **Collected:** 10/18/2016 **Lab ID:** 0076

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-077  
 325 **Collected:** 10/18/2016 **Lab ID:** 0077

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.20	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011607647

CustomerID: CLCS25

CustomerPO: 170771

ProjectID: PO 170771

Attn: **Brian Logel**  
**Clarence Central Schools**  
**9625 Main Street**  
**Clarence, NY 14031**

Phone: (716) 407-9131  
 Fax: (716) 407-9137  
 Received: 11/02/16 10:00 AM

Project: High School

**Analytical Results**

**Client Sample Description** HS-078  
325 BOYS LAV **Collected:** 10/18/2016 **Lab ID:** 0078

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-079  
325 GIRLS LAV **Collected:** 10/18/2016 **Lab ID:** 0079

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-080  
326 **Collected:** 10/18/2016 **Lab ID:** 0080

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.93	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-081  
326 **Collected:** 10/18/2016 **Lab ID:** 0081

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-082  
326 BOYS LAV **Collected:** 10/18/2016 **Lab ID:** 0082

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-083  
326 GIRLS LAV **Collected:** 10/18/2016 **Lab ID:** 0083

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-084  
WOMENS FACULTY LAV (RIGHT) **Collected:** 10/18/2016 **Lab ID:** 0084

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	011607647
CustomerID:	CLCS25
CustomerPO:	170771
ProjectID:	PO 170771

Attn: **Brian Logel**  
**Clarence Central Schools**  
**9625 Main Street**  
**Clarence, NY 14031**

Phone: (716) 407-9131  
 Fax: (716) 407-9137  
 Received: 11/02/16 10:00 AM

Project: **High School****Analytical Results**

**Client Sample Description** HS-085  
 WOMENS FACULTY LAV (LEFT) **Collected:** 10/18/2016 **Lab ID:** 0085

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-086  
 MENS FACULTY LAV (RIGHT) **Collected:** 10/18/2016 **Lab ID:** 0086

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.69	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-087  
 MENS FACULTY LAV (LEFT) **Collected:** 10/18/2016 **Lab ID:** 0087

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.67	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-088  
 330 **Collected:** 10/18/2016 **Lab ID:** 0088

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-089  
 LIBRARY TOP FLOOR **Collected:** 10/18/2016 **Lab ID:** 0089

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-090  
 LIBRARIANS OFFICE **Collected:** 10/18/2016 **Lab ID:** 0090

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-091  
 LIBRARY HALL **Collected:** 10/18/2016 **Lab ID:** 0091

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	011607647
CustomerID:	CLCS25
CustomerPO:	170771
ProjectID:	PO 170771

Attn: **Brian Logel**  
**Clarence Central Schools**  
**9625 Main Street**  
**Clarence, NY 14031**

Phone: (716) 407-9131  
 Fax: (716) 407-9137  
 Received: 11/02/16 10:00 AM

Project: **High School****Analytical Results**

**Client Sample Description** HS-092  
 LIBRARY HALL- GIRLS LAV - RIGHT  
**Collected:** 10/18/2016 **Lab ID:** 0092

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.51	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-093  
 LIBRARY HALL- GIRLS LAV - LEFT  
**Collected:** 10/18/2016 **Lab ID:** 0093

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-094  
 BACKSTAGE GIRLS LAV  
**Collected:** 10/18/2016 **Lab ID:** 0094

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	45.9	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-100  
 FACULTY WOMENS LAV  
**Collected:** 10/18/2016 **Lab ID:** 0095

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.79	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-101  
 DRINK FOUNTAIN  
**Collected:** 10/18/2016 **Lab ID:** 0096

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.60	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-102  
 MENS LAV  
**Collected:** 10/18/2016 **Lab ID:** 0097

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-103  
 SPEC. ED SINK  
**Collected:** 10/18/2016 **Lab ID:** 0098

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.43	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	011607647
CustomerID:	CLCS25
CustomerPO:	170771
ProjectID:	PO 170771

Attn: **Brian Logel**  
**Clarence Central Schools**  
**9625 Main Street**  
**Clarence, NY 14031**

Phone: (716) 407-9131  
 Fax: (716) 407-9137  
 Received: 11/02/16 10:00 AM

Project: High School

**Analytical Results**

**Client Sample Description** HS-104  
 TECHNOLOGY BATHROOM  
**Collected:** 10/18/2016 **Lab ID:** 0099

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.33	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-105  
 LEFT SIDE SINK 510  
**Collected:** 10/18/2016 **Lab ID:** 0100

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.11	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-106  
 RM 510 RIGHT SINK  
**Collected:** 10/18/2016 **Lab ID:** 0101

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.20	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-107  
 ROM 507 SINK  
**Collected:** 10/18/2016 **Lab ID:** 0102

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.81	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-108  
 RM 506 SINK 1  
**Collected:** 10/18/2016 **Lab ID:** 0103

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.53	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-109  
 RM 506 SINK 2  
**Collected:** 10/18/2016 **Lab ID:** 0104

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-110  
 RM 508 LEFT SINK  
**Collected:** 10/18/2016 **Lab ID:** 0105

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.79	1.00	µg/L	12/19/2016	CB	12/20/2016	BB



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011607647

CustomerID: CLCS25

CustomerPO: 170771

ProjectID: PO 170771

Attn: **Brian Logel**  
**Clarence Central Schools**  
**9625 Main Street**  
**Clarence, NY 14031**

Phone: (716) 407-9131  
 Fax: (716) 407-9137  
 Received: 11/02/16 10:00 AM

Project: High School

**Analytical Results**

**Client Sample Description** HS-111  
 RM 508 RT SINK  
**Collected:** 10/18/2016 **Lab ID:** 0106

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	20.7	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-112  
 DRINK FOUNTAIN BETWEEN 506/508  
**Collected:** 10/18/2016 **Lab ID:** 0107

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-113  
 RM 506 ICE MACHINE  
**Collected:** 10/18/2016 **Lab ID:** 0108

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	48.5	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-114  
 RM 501 SINK 1  
**Collected:** 10/18/2016 **Lab ID:** 0109

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	90.9	5.00	µg/L	12/19/2016	LY	12/19/2016	BB

**Client Sample Description** HS-115  
 RM 501 SINK 2  
**Collected:** 10/18/2016 **Lab ID:** 0110

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	11.6	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-116  
 RM 503 SINK  
**Collected:** 10/18/2016 **Lab ID:** 0111

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-117  
 RM 504 LEFT SINK  
**Collected:** 10/18/2016 **Lab ID:** 0112

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011607647

CustomerID: CLCS25

CustomerPO: 170771

ProjectID: PO 170771

Attn: **Brian Logel**  
**Clarence Central Schools**  
**9625 Main Street**  
**Clarence, NY 14031**

Phone: (716) 407-9131  
 Fax: (716) 407-9137  
 Received: 11/02/16 10:00 AM

Project: **High School****Analytical Results**

**Client Sample Description** HS-118  
 RM 504 RIGHT SINK  
**Collected:** 10/18/2016 **Lab ID:** 0113

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-119  
 WOMENS FACULTY SINK  
**Collected:** 10/18/2016 **Lab ID:** 0114

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-120  
 GIRLS LAV SINK 1  
**Collected:** 10/18/2016 **Lab ID:** 0115

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-121  
 GIRLS LAV SINK 2  
**Collected:** 10/18/2016 **Lab ID:** 0116

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-122  
 GIRLS LAV SINK 3  
**Collected:** 10/18/2016 **Lab ID:** 0117

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-123  
 BOYS LAV LEFT  
**Collected:** 10/18/2016 **Lab ID:** 0118

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.55	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-124  
 BOYS LAV CENTER  
**Collected:** 10/18/2016 **Lab ID:** 0119

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.49	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011607647

CustomerID: CLCS25

CustomerPO: 170771

ProjectID: PO 170771

Attn: **Brian Logel**  
**Clarence Central Schools**  
**9625 Main Street**  
**Clarence, NY 14031**

Phone: (716) 407-9131  
 Fax: (716) 407-9137  
 Received: 11/02/16 10:00 AM

Project: High School

**Analytical Results**

**Client Sample Description** HS-125  
BOYS LAV RIGHT **Collected:** 10/18/2016 **Lab ID:** 0120

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-126  
HC LAV NEAR 408 **Collected:** 10/18/2016 **Lab ID:** 0121

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-127  
RM 408 STATION 2 **Collected:** 10/18/2016 **Lab ID:** 0122

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.08	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-128  
DRINK NEAR RM 410 **Collected:** 10/18/2016 **Lab ID:** 0123

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.03	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-129  
RM 410 SINK **Collected:** 10/18/2016 **Lab ID:** 0124

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.78	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-130  
WOMEN FACULTY NEAR 410 **Collected:** 10/18/2016 **Lab ID:** 0125

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	32.8	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-131  
WOMEN FACULTY NEAR 410 **Collected:** 10/18/2016 **Lab ID:** 0126

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	22.5	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	011607647
CustomerID:	CLCS25
CustomerPO:	170771
ProjectID:	PO 170771

Attn: **Brian Logel**  
**Clarence Central Schools**  
**9625 Main Street**  
**Clarence, NY 14031**

Phone: (716) 407-9131  
 Fax: (716) 407-9137  
 Received: 11/02/16 10:00 AM

Project: **High School****Analytical Results**

**Client Sample Description** HS-132  
 WOMEN FACULTY NEAR 410  
**Collected:** 10/18/2016 **Lab ID:** 0127

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	21.8	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-133  
 MEN FACULTY NEAR 412  
**Collected:** 10/18/2016 **Lab ID:** 0128

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.45	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-134  
 MEN FACULTY NEAR 412  
**Collected:** 10/18/2016 **Lab ID:** 0129

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	13.0	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-135  
 MEN FACULTY NEAR 412  
**Collected:** 10/18/2016 **Lab ID:** 0130

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	23.5	1.00	µg/L	12/20/2016	CB	12/20/2016	BB

**Client Sample Description** HS-136  
 MEN FACULTY NEAR 412  
**Collected:** 10/18/2016 **Lab ID:** 0131

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	30.4	1.00	µg/L	12/20/2016	CB	12/20/2016	BB

**Client Sample Description** HS-137  
 RM 412 SINK  
**Collected:** 10/18/2016 **Lab ID:** 0132

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/20/2016	BB

**Client Sample Description** HS-138  
 RM 432 SINK 1  
**Collected:** 10/18/2016 **Lab ID:** 0133

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/20/2016	CB	12/20/2016	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011607647

CustomerID: CLCS25

CustomerPO: 170771

ProjectID: PO 170771

Attn: **Brian Logel**  
**Clarence Central Schools**  
**9625 Main Street**  
**Clarence, NY 14031**

Phone: (716) 407-9131  
 Fax: (716) 407-9137  
 Received: 11/02/16 10:00 AM

Project: High School

**Analytical Results**

**Client Sample Description** HS-139  
 RM 432 SINK 2 **Collected:** 10/18/2016 **Lab ID:** 0134

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.22	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-140  
 420 SINK 1 **Collected:** 10/18/2016 **Lab ID:** 0135

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.81	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-141  
 RM 435 CENTER **Collected:** 10/18/2016 **Lab ID:** 0136

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	11.8	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-142  
 RM 435 HALLWAY **Collected:** 10/18/2016 **Lab ID:** 0137

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.58	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-143  
 FOUNTAIN NEAR 436 **Collected:** 10/18/2016 **Lab ID:** 0138

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.39	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-144  
 FOUNTAIN NEAR 444 **Collected:** 10/18/2016 **Lab ID:** 0139

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	9.14	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-145  
 RM 437 SINK **Collected:** 10/18/2016 **Lab ID:** 0140

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011607647

CustomerID: CLCS25

CustomerPO: 170771

ProjectID: PO 170771

Attn: **Brian Logel**  
**Clarence Central Schools**  
**9625 Main Street**  
**Clarence, NY 14031**

Phone: (716) 407-9131  
 Fax: (716) 407-9137  
 Received: 11/02/16 10:00 AM

Project: **High School****Analytical Results**

**Client Sample Description** HS-146  
 RM CENTER SCIENCE AREA  
**Collected:** 10/18/2016 **Lab ID:** 0141

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.23	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-147  
 RM 423 SINK  
**Collected:** 10/18/2016 **Lab ID:** 0142

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-148  
 RM 422 SINK  
**Collected:** 10/18/2016 **Lab ID:** 0143

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.33	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-149  
 RM 421 SINK  
**Collected:** 10/18/2016 **Lab ID:** 0144

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.31	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-150  
 DRINK FOUNTAIN NEAR 421  
**Collected:** 10/18/2016 **Lab ID:** 0145

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-151  
 BOYS LAV RAMP HALL  
**Collected:** 10/18/2016 **Lab ID:** 0146

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.41	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-152  
 BOYS LAV RAMP HALL  
**Collected:** 10/18/2016 **Lab ID:** 0147

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.02	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011607647

CustomerID: CLCS25

CustomerPO: 170771

ProjectID: PO 170771

Attn: **Brian Logel**  
**Clarence Central Schools**  
**9625 Main Street**  
**Clarence, NY 14031**

Phone: (716) 407-9131  
 Fax: (716) 407-9137  
 Received: 11/02/16 10:00 AM

Project: **High School****Analytical Results**

**Client Sample Description** HS-153  
 GIRLS LAV RAMP HALL-L **Collected:** 10/18/2016 **Lab ID:** 0148

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.29	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-154  
 GIRLS LAV RAMP HALL-R **Collected:** 10/18/2016 **Lab ID:** 0149

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.15	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-155  
 DIST. OFC MENS 1 **Collected:** 10/18/2016 **Lab ID:** 0150

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.77	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-156  
 MENS 2 **Collected:** 10/18/2016 **Lab ID:** 0151

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	9.17	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-157  
 DIST. OFC KITCHEN **Collected:** 10/18/2016 **Lab ID:** 0152

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.47	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-158  
 WOMENS DIST. OFC 1 **Collected:** 10/18/2016 **Lab ID:** 0153

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.63	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-159  
 WOMENS DIST. OFC 2 **Collected:** 10/18/2016 **Lab ID:** 0154

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.54	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	011607647
CustomerID:	CLCS25
CustomerPO:	170771
ProjectID:	PO 170771

Attn: **Brian Logel**  
**Clarence Central Schools**  
**9625 Main Street**  
**Clarence, NY 14031**

Phone: (716) 407-9131  
 Fax: (716) 407-9137  
 Received: 11/02/16 10:00 AM

Project: High School

**Analytical Results**

**Client Sample Description** HS-160  
DIST OFC SUPER OFC  
**Collected:** 10/18/2016 **Lab ID:** 0155

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-161  
EXTERIOR HOSE BIB  
**Collected:** 10/18/2016 **Lab ID:** 0156

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.90	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-162  
RIFLE RANGE STAIR SINK  
**Collected:** 10/18/2016 **Lab ID:** 0157

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-163  
LIBRARY GANG LAV MENS 1  
**Collected:** 10/18/2016 **Lab ID:** 0158

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.94	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-164  
LIBRARY GANG LAV MENS 2  
**Collected:** 10/18/2016 **Lab ID:** 0159

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-165  
STAGE LAV MENS  
**Collected:** 10/18/2016 **Lab ID:** 0160

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	10.3	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-166  
HS OFFICE PRINCIPAL SINK  
**Collected:** 10/18/2016 **Lab ID:** 0161

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	19.1	1.00	µg/L	12/19/2016	CB	12/20/2016	BB



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011607647

CustomerID: CLCS25

CustomerPO: 170771

ProjectID: PO 170771

Attn: **Brian Logel**  
**Clarence Central Schools**  
**9625 Main Street**  
**Clarence, NY 14031**

Phone: (716) 407-9131  
 Fax: (716) 407-9137  
 Received: 11/02/16 10:00 AM

Project: High School

**Analytical Results**

**Client Sample Description** HS-167  
NURSE 106 SINK **Collected:** 10/18/2016 **Lab ID:** 0162

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-168  
NURSE 106 BREAKROOM **Collected:** 10/18/2016 **Lab ID:** 0163

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-169  
GUIDANCE KITCHEN **Collected:** 10/18/2016 **Lab ID:** 0164

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-170  
115 DRINK FOUNTAIN **Collected:** 10/18/2016 **Lab ID:** 0165

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.62	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-171  
MAIN **Collected:** 10/18/2016 **Lab ID:** 0166

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.35	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-172  
200 HALL FOUNTAIN **Collected:** 10/18/2016 **Lab ID:** 0167

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.32	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-173  
WOMENS LAV 2ND FLOOR **Collected:** 10/18/2016 **Lab ID:** 0168

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	16.0	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	011607647
CustomerID:	CLCS25
CustomerPO:	170771
ProjectID:	PO 170771

Attn: **Brian Logel**  
**Clarence Central Schools**  
**9625 Main Street**  
**Clarence, NY 14031**

Phone: (716) 407-9131  
 Fax: (716) 407-9137  
 Received: 11/02/16 10:00 AM

Project: High School

**Analytical Results**

**Client Sample Description** HS-174  
 WOMEN LAV NEAR RM 217  
**Collected:** 10/18/2016 **Lab ID:** 0169

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.46	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-175  
 WOMEN LAV NEAR RM 217  
**Collected:** 10/18/2016 **Lab ID:** 0170

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.44	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-176  
 WOMEN LAV NEAR RM 217  
**Collected:** 10/18/2016 **Lab ID:** 0171

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.42	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-177  
 WOMEN LAV NEAR RM 217  
**Collected:** 10/18/2016 **Lab ID:** 0172

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	10.8	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-178  
 MENS FACULTY 1  
**Collected:** 10/18/2016 **Lab ID:** 0173

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-179  
 MENS FACULTY 2  
**Collected:** 10/18/2016 **Lab ID:** 0174

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.74	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-180  
 DRINK FOUNTAIN 1  
**Collected:** 10/18/2016 **Lab ID:** 0175

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.06	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011607647  
 CustomerID: CLCS25  
 CustomerPO: 170771  
 ProjectID: PO 170771

Attn: **Brian Logel**  
**Clarence Central Schools**  
**9625 Main Street**  
**Clarence, NY 14031**

Phone: (716) 407-9131  
 Fax: (716) 407-9137  
 Received: 11/02/16 10:00 AM

Project: **High School**

**Analytical Results**

**Client Sample Description** HS-181  
 DRINK FOUNTAIN 2 **Collected:** 10/18/2016 **Lab ID:** 0176

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-182  
 FACULTY WOMENS 1 **Collected:** 10/18/2016 **Lab ID:** 0177

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-183  
 FACULTY WOMENS 2 **Collected:** 10/18/2016 **Lab ID:** 0178

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-184  
 BASEMENT PUMP SINK **Collected:** 10/18/2016 **Lab ID:** 0179

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.54	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-185  
 DRINK FT **Collected:** 10/18/2016 **Lab ID:** 0180

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.50	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-186  
 CONCESSION STAND SINK L **Collected:** 10/18/2016 **Lab ID:** 0181

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.46	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-187  
 CONCESSION STAND SINK C **Collected:** 10/18/2016 **Lab ID:** 0182

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.77	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011607647

CustomerID: CLCS25

CustomerPO: 170771

ProjectID: PO 170771

Attn: **Brian Logel**  
**Clarence Central Schools**  
**9625 Main Street**  
**Clarence, NY 14031**

Phone: (716) 407-9131  
 Fax: (716) 407-9137  
 Received: 11/02/16 10:00 AM

Project: High School

**Analytical Results**

**Client Sample Description** HS-188  
 CONCESSION STAND SINK R  
**Collected:** 10/18/2016 **Lab ID:** 0183

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.06	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-189  
 MEN CONCESSION SINK 1  
**Collected:** 10/18/2016 **Lab ID:** 0184

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.65	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-190  
 MEN CONCESSION SINK 2  
**Collected:** 10/18/2016 **Lab ID:** 0185

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.51	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-191  
 MEN CONCESSION SINK 3  
**Collected:** 10/18/2016 **Lab ID:** 0186

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.74	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-192  
 OUTSIDE FOUNTAIN  
**Collected:** 10/18/2016 **Lab ID:** 0187

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.42	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-193  
 EXTERIOR HOSE BIB  
**Collected:** 10/18/2016 **Lab ID:** 0188

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.99	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Client Sample Description** HS-194  
 CONCESSION STAND SINK  
**Collected:** 10/18/2016 **Lab ID:** 0189

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	12.8	1.00	µg/L	12/19/2016	CB	12/20/2016	BB

**Definitions:**

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)